



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, South Dinajpur**  
**West Bengal Fire & Emergency Services**  
**Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134**

Memo no.: FSR/0125186210700005

Date: 19-02-2021

**From:**

**Divisional Fire Officer, South Dinajpur**  
**West Bengal Fire & Emergency Services**

**To: BIDYESWARI TEACHERS TRAINING COLLEGE**

**VILL-DAFARPUR, P.O-CHAMPATALI, P.S-GANGARAMPUR, DIST-DAKSHIN DINAJPUR, PIN-733124, UNDER MOUZA-DAFARPUR**

**Sub: Issuance of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied educational building under group of Institutional at the premises no-BIDYESWARI TEACHERS TRAINING COLLEGE, Vill-Dafarpur, P.o-Champatali, P.s-Gangarampur, Dist-Dakshin Dinajpur, Pin-733124, Under Mouza-Dafarpur.**

This is in reference to your application no. 0125189210700011 dated 17-02-2021 regarding the Issuance of Fire Safety Certificate for the occupancy of an existing construction of G+2 storied educational building under group of Institutional at the premises no-BIDYESWARI TEACHERS TRAINING COLLEGE, Vill-Dafarpur, P.o-Champatali, P.s-Gangarampur, Dist-Dakshin Dinajpur, Pin-733124, Under Mouza-Dafarpur.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

Recommendation.

However, to keep up the Fire Safety Measures of the aforesaid building, the following safety measures need to be incorporated.

- 1) A standby fire pump of adequate capacity shall have to be installed.
- 2) The interior finish decoration of the building shall be made with low flame spread materials conforming to the I.S Specification.
- 3) To eliminate risk of fire hazards, good house keeping both for inside and outside building shall be strictly maintained.
- 4) Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them. If require the old electrical lines shall be replaced with new electrical lines, cables shall always be laid in M.S conduit pipes continuously bonded to the earth.
- 5) The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.

- 6)The employee and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
- 7)Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8)First-Aid-Fire fighting system shall be provided as per I.S. Specifications.
- 9)Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them to perfectly good working condition at all times.
- 10)The Fire safety certificates is valid for Three years and has to be renewed after three years from the date of issue of this letter. As per Govt. of West Bengal Vide Notification No- 629\_L, Dated-17/04/2018

Signature valid

Signed by: MALAY K ROUSH  
Reason: Approval  
Location: West Bengal  
Date: 19-Feb-2021 16:57:54

Divisional Fire Officer, South Dinajpur  
West Bengal Fire & Emergency Services